


ProSpex Flare90 Part L Compliant Accent Downlight


TM65.2	11kgCO2e
TM66	2.3 CEAM



92mm (3.62") overall diameter. 360° rotation. Up to 30° tilt. Available with standard trim kit or plaster-in kit for flush appearance. Family of matching products also available. Required depth height + 25mm^



933-FL-LED + 9000-PBZ Cut-out 83mm Ø



933-FL-LED + 9000-PCZ Cut-out 83mm Ø

LED Source	LED51/Q-HO	LED51/Q-HO	LED51/Q-HO	LED51/Q-HO	11
CCT	3000K	3000K	3000K	3000K	
Drive Current	350mA	350mA	350mA	350mA	≥75 Dwe∎ings Compliant
Power inc Driver	14.0W	14.0W	14.0W	14.0W	_
Beam Angle	NF (18°)	MF (25°)	FL(35°)	WFL (55°)	17
Delivered Lumens	1736	1731	1707	1778	≥95 General
Delivered Intensisty cd	12001	7497	4660	2411	Compliant
Delivered Lumens per circuit watt	124	124	122	127	
Forward Volt	34V	34V	33V	34V	Z
CRI	≥93 CRI	≥93 CRI	≥93 CRI	≥93 CRI	≥80 Display Compliant


Lumen output for other CCTs use the following multification factors to the 3000K figures above: 2700K x 0.98. 4000K x 1.02

lucent_®

Project Ref:		Location Ref:
Fixture Ord	er Code: 933-FL-LED –	
Fixture – 933-FL-LED	Flare90 Accent with LED51	
Finish — WH BK RAL ABR1 ABZ1 PCH1 PNK1 PBR1	White Black Custom RAL Finish* Antique Brass Antique Bronze Polished Chrome Polished Nickel Polished Brass	
IP Rating 44 54	IP44 IP54	
Installation Installation 9000-PBZ 9000-PCZ	Order Code:	ince
Module Ord	der Code: LED51/Q-HO –	
LED – LED51/Q-HO		
CCT – 27 30 40	2700K 3000K 4000K***	
Beam – NF FL WFL	Narrow Flood Medium Flood Flood Wide Flood	
***contact Luce	nt for availability	
Driver Optic Protocol — A P D B	Non-Dim Analogue (0-10v) Phase DALI Bluetooth**	Emergency Options: Emergency ED ED ES Maintained 3hr Emergency Maintained 3hr DALI Self Test Maintained 3hr Self Test

lucent

Finish selection



lucent

Technical Details

*Custom RAL code must be specified. Custom RAL colours can increase prices and lead times

Dimming. Whilst Lucent can offer the majority of its luminaires with various dimming options, it remains the responsibility of the specifier/installer to check and ensure compatibility of any control equipment used. Additional cabling may be required depending on the dimming protocol specified.

**Bluetooth (wireless) is the communication method. The exact dimming protocol must be confirmed to allow the selection of suitable drivers or bluetooth devices.

^ Depth indicated is the minimum recess depth for the luminaire with a remote mounted LED driver. Installing a driver through either the luminaire cut-out or installation kit may require additional recess depth, please refer to the relevant luminaire installation instructions for further details.Data correct at time of publishing

First Fix Requirement. Luminaire comprised of fixture body with ceiling trim and installation kit, which is to be fitted into the ceiling once finished. Ensure correct alignment of the installation kit before final assembly (see luminaire instllation instructions for details)

IP Rating. Tested from underside of the ceiling

Note that the picture of the finishes provided is for illustrative purposes only. The finishes may vary in colour, texture and appearance. Contact Lucent lighting Ltd for more information.

It is the policy of Lucent Lighting to continually review and improve its products and therefore reserve the right to change any details of product or withdraw specifications without prior notice.

Luminaires designed to comply with EN60598 and all other standards.

This specification sheet supersededs all previous versions.

All intellectual property rights pertaining to the product described above and to this document are owned by or licensed to Lucent Lighting Ltd.

We reserve the right to take whatever action is necessary to protect those intellectual property rights.