lucent_®




QUANTUM Module

ProSpex PlusMini Part L Compliant Fixed Downlight

TM65.2	11kgCO2e
TM66	2.3 CEAM



80mm (3.15") overall trimless diameter. Available with standard trim kit or plaster-in kit options. Family of matching products also available. Required depth = height + 25mm^



750+LED-TL/PCZ Cut-out 82mm Ø

LED Source	LED51/Q-HO	LED51/Q-HO	LED51/3-HO	LED51/Q-HO
CCT	3000K	3000K	3000K	3000K
Drive Current	350mA	350mA	350mA	350mA
Power inc Driver	14.0W	14.0W	14.0W	14.0W
Beam Angle	NF (18°)	MF (25°)	FL(33°)	WFL (51°)
Delivered Lumens	1669	1712	1681	1730
Delivered Intensisty cd	11710	7753	5309	2346
Delivered Lumens per circuit watt	119	122	120	124
Forward Volt	34V	34V	34V	34V
CRI	≥93 CRI	≥93 CRI	≥93 CRI	≥93 CRI


Lumen output for other CCTs use the following multification factors to the 3000K figures above: 2700K x 0.98. 4000K x 1.02

lucent_®

Project Ref:	Location Ref:			
Fixture Ord	er Code: 750+LED-TL –			
Fixture – 750+LED-TL	Plus Mini Conical Fixed Trimless with LED51			
Installation ^{750+TL} 750+PCZ Finish	TL trimless kit PCZ Plaster kit			
WH01 BK01 RL99* ABR1 ABZ1 PCH1 PNK1 PBR1	White RAL 9010 Black RAL 9005 Custom RAL Colour* Antique Brass Antique Bronze Polished Chrome Polished Nickel Polished Brass			
IP Rating 44 54	IP44 IP54			
750- Trimle Front fittin	+PCZ ess Kit ng, full skim	m		
Module Order Code: LED51/Q-HO – –				
LED – LED51/Q-HO	LED50 ONE QUANTUM HE High Output			
CCT – 27 30 40	2700K 3000K 4000K***			
Beam – NF MF FL WFL	Narrow Flood Medium Flood Flood Wide Flood			
***contact Luce	nt for availability			
Driver Opti Protocol – S A P D B	ONS: Non-Dim Analogue (0-10v) Phase DALI Bluetooth**	Emergency Options: Emergency ED ED ES Maintained 3hr Emergency Maintained 3hr DALI Self Test Maintained 3hr Self Test		

lucent

Finish selection



lucent

Technical Details

*Custom RAL code must be specified. Custom RAL colours can increase prices and lead times

Dimming. Whilst Lucent can offer the majority of its luminaires with various dimming options, it remains the responsibility of the specifier/installer to check and ensure compatibility of any control equipment used. Additional cabling may be required depending on the dimming protocol specified.

**Bluetooth (wireless) is the communication method. The exact dimming protocol must be confirmed to allow the selection of suitable drivers or bluetooth devices.

^ Depth indicated is the minimum recess depth for the luminaire with a remote mounted LED driver. Installing a driver through either the luminaire cut-out or installation kit may require additional recess depth, please refer to the relevant luminaire installation instructions for further details.Data correct at time of publishing

First Fix Requirement. Luminaire comprised of fixture body with ceiling trim and installation kit, which is to be fitted into the ceiling once finished. Ensure correct alignment of the installation kit before final assembly (see luminaire instllation instructions for details)

IP Rating. Tested from underside of the ceiling

Note that the picture of the finishes provided is for illustrative purposes only. The finishes may vary in colour, texture and appearance. Contact Lucent lighting Ltd for more information.

It is the policy of Lucent Lighting to continually review and improve its products and therefore reserve the right to change any details of product or withdraw specifications without prior notice.

Luminaires designed to comply with EN60598 and all other standards.

This specification sheet supersededs all previous versions.

All intellectual property rights pertaining to the product described above and to this document are owned by or licensed to Lucent Lighting Ltd.

We reserve the right to take whatever action is necessary to protect those intellectual property rights.