lucent_®




Mix85 Duo Accent Trim Part L Compliant Downlight





Ø85mm (3.35") overall trim. Ø55mm (2.17") aperture. Available with standard trim kit or plaster-in kit for flush appearance. Family of matching products also available.



Mix85 Duo with Trim Kit TR1 Cut-out Ø80mm. Required depth height+25mm.

LED Source	LED51/Q-HO	LED51/Q-HO	LED51/Q-HO	LED51/Q-HO	
CCT	3000K	3000K	3000K	3000K	
Drive Current	350mA	350mA	350mA	350mA	≥75 Dwellings Compliant
Power inc Driver	14W	14W	14W	14W	
Beam Angle	NF (17°)	MF (25°)	FL(35°)	WFL (55°)	
Delivered Lumens	1688	1747	1722	1612	
Delivered Intensisty cd	12170	10090	4790	2105	≥95 General Compliant
Delivered Lumens per circuit watt	120	124	123	115	_
Forward Volt	33V	33V	33V	33V	12
CRI	≥95 CRI	≥95 CRI	≥95 CRI	≥95 CRI	≥80 Display Compliant

Apply these factors to 3000K for lumen output of other CCTs: 2700K x 0.98 / 4000K x 1.02.

lucent®

Project Ref:				Locatior	n Ref:			
Fixture Ord	er Code:	MX85010-DU	- TR1				- 0	
Fixture MX85010-DU	Mix85 Duo Ac	 cent for LED						
Installation TR1	Trim for Existing Ceilings							
Finish								
WH02 BK02 RL99* ABR1 ABZ1 PCH1 PNK1 PBR1	White RAL 90 Black RAL 900 Custom RAL (Antique Brass Antique Bronz Polished Chro Polished Nick Polished Brass	ze ime el						
IP Rating 54 65	IP54 IP65							
LED Order	Code:	LED51/Q-HO] – [-] — T	
LED led <i>5</i> 1/q-ho	LED50 ONE C	QUANTUM HE High	Output					
CCT 27 30 40***	90 CRI 2700k 90 CRI 3000k 90 CRI 4000k	<						
Beam NF FL WFL	Narrow Flood Medium Flood Flood Wide Flood	1						
Driver Optio Protocol A P D B	ONS: Non-Dim Analogue (0-10 Phase DALI Bluetooth**	 Ov)]					
Emergency Emergency ED ES	Maintained 3h Maintained 3h Maintained 3h]					

lucent

Finish selection



Antique Brass



Polished Nickel

Accessories



Honeycomb Louvre



Heavy Spread Lens

Accessories Order Code:

/Lens ——
Honeycomb Louvre Diffusing Lens Frosted Lens
Frosted Lens
Linear Spread Lens
Heavy Spread Lens



Antique Bronze



Polished Chrome



Diffusing Lens



Polished Brass

Frosted Lens



Linear Spread Lens

Technical Details

*Custom RAL code must be specified. Custom RAL colours can increase prices and lead times

Dimming. Whilst Lucent can offer the majority of its luminaires with various dimming options, it remains the responsibility of the specifier/installer to check and ensure compatibility of any control equipment used. Additional cabling may be required depending on the dimming protocol specified.

**Bluetooth (wireless) is the communication method. The exact dimming protocol must be confirmed to allow the selection of suitable drivers or bluetooth devices.

^ Depth indicated is the minimum recess depth for the luminaire with a remote mounted LED driver. Installing a driver through either the luminaire cut-out or installation kit may require additional recess depth, please refer to the relevant luminaire installation instructions for further details.Data correct at time of publishing

First Fix Requirement. Luminaire comprised of fixture body with ceiling trim and installation kit, which is to be fitted into the ceiling once finished. Ensure correct alignment of the installation kit before final assembly (see luminaire instllation instructions for details)

IP Rating. Tested from underside of the ceiling

Note that the picture of the finishes provided is for illustrative purposes only. The finishes may vary in colour, texture and appearance. Contact Lucent lighting Ltd for more information.

It is the policy of Lucent Lighting to continually review and improve its products and therefore reserve the right to change any details of product or withdraw specifications without prior notice.

Luminaires designed to comply with EN60598 and all other standards.

This specification sheet supersededs all previous versions.

All intellectual property rights pertaining to the product described above and to this document are owned by or licensed to Lucent Lighting Ltd.

We reserve the right to take whatever action is necessary to protect those intellectual property rights.

Please notify Lucent Lighting Ltd of any inaccuracies immediately. E&OE