## lucent®




### Mix60 Flare Accent Trim

TM65.2 3kgCO2e

TM66 2.5 CEAM



Ø62mm (2,44") overall trim, Ø28mm (1,10") aperture. Up to 30° tilt. Available with a standard trim kit or 3 flush trim options, depending on ceiling type and finish.



Mix60 Flare with Trim Kit TR1 <sup>(1)</sup>. Cut-out Ø56mm.
Required depth height +15mm.

LED Source	LED35/Q-HO	LED35/Q-HO	LED35/Q-HO	LED35/Q-HO	1 4
CCT	3000K	3000K	3000K	3000K	
Drive Current	250mA	250mA	250mA	250mA	≥75 Dwellings Compliant
Power inc Driver	9.7W	9.7W	9.7W	9.7W	
Beam Angle	NF (17°)	MF (23°)	FL (32°)	WFL (48°)	
Delivered Lumens	866	969	910	750	≥95 Gener
Delivered Intensisty cd	6166	5633	2977	1101	Complian
Delivered Lumens per circuit watt	89	99	93	77	
Forward Volt	33V	33V	33V	33V	1 '/
CRI	≥90 CRI	≥90 CRI	≥90 CRI	≥90 CRI	≥80 Displ Complia

Apply these factors to 3000 K for lumen output of other CCTs:  $2700 \text{K} \times 0.98 / 4000 \text{K} \times 1.02$ .



Project Ref: Location Ref:						
Please only	complete one of the following code builders					
Non Fire Ra	ted Code Builder					
Fixture Ord	er Code: MX60010-FL					
Fixture MX60010-FL	Mix60 Flare Accent					
Installation (1) TR1 TR2 (2)	Trim for Existing Ceilings 5-15mm total thickness Trim for Existing Ceilings 15-28mm total thickness					
Finish WH02 BK02 RAL* ABR1 ABZ1 PCH1 PNK1 PBR1	White RAL 9010 Black RAL 9005 Custom RAL Colour* Antique Brass Antique Bronze Polished Chrome Polished Nickel Polished Brass					
IP Rating 54 65	IP54 IP65					
Rating 0	No Fire Rating					
Fire Rated (	Code Builder					
Fixture Ord	er Code: MX60010-FL - TR2 - FR					
Fixture MX60010-FL	Mix60 Flare Accent for LED					
Installation (1) TR2 <sup>(2)</sup>	Trim for Existing Ceilings 15-28mm total thickness					
Finish WH02 BK02 RAL* ABR1 ABZ1 PCH1 PNK1 PBR1	White RAL 9010 Black RAL 9005 Custom RAL Colour* Antique Brass Antique Bronze Polished Chrome Polished Nickel Polished Brass					
IP Rating 54 65	IP54 IP65					
Rating FR (3)	Fire Rated					

(1) For any ceiling thickness or construction type not shown please contact Lucent

(3) Tested and approved to EN 1363-1:2020 and EN 1365-2:2014 for 60 minutes fire rating.

(2) Adjustment may be limited in thicker ceiling constructions. Refer to installation instructions for details.

Issued: 08/25



Project Ref:		Location Ref:						
LED Order	Code: LED35/Q-HO -							
LED LED35/Q-HO	LED35 QUANTUM High Output							
CCT 27 30 40 (4)	90 CRI 2700K 90 CRI 3000K 90 CRI 4000K							
Beam NF MF FL WFL	Narrow Flood Medium Flood Flood Wide Flood							
<sup>(4)</sup> contact Lucent for availability								
Driver Opti	ons:	Emergency	Options:					
Protocol S A P D B	Non-Dim Analogue (0-10v) Phase DALI Bluetooth**	Emergency E ED ES	Maintained 3hr Emergency Maintained 3hr DALI Self Test Maintained 3hr Self Test					

Issued: 08/25

# lucent®

### Finish selection



Antique Brass



Antique Bronze



Polished Brass



Polished Nickel



Polished Chrome

### Accessories



Honeycomb Louvre



Diffusing Lens



Frosted Lens

Issued: 08/25



Heavy Spread Lens



Linear Spread Lens

Accessories Order Code:

Louvre/Lens

Honeycomb Louvre Diffusing Lens Frosted Lens Linear Spread Lens Heavy Spread Lens



#### **Technical Details**

\*Custom RAL code must be specified. Custom RAL colours can increase prices and lead times

Dimming. Whilst Lucent can offer the majority of its luminaires with various dimming options, it remains the responsibility of the specifier/installer to check and ensure compatibility of any control equipment used. Additional cabling may be required depending on the dimming protocol specified.

- \*\*Bluetooth (wireless) is the communication method. The exact dimming protocol must be confirmed to allow the selection of suitable drivers or bluetooth devices.
- ^ Depth indicated is the minimum recess depth for the luminaire with a remote mounted LED driver. Installing a driver through either the luminaire cut-out or installation kit may require additional recess depth, please refer to the relevant luminaire installation instructions for further details. Data correct at time of publishing

First Fix Requirement. Luminaire comprised of fixture body with ceiling trim and installation kit, which is to be fitted into the ceiling once finished. Ensure correct alignment of the installation kit before final assembly (see luminaire instllation instructions for details)

IP Rating. Tested from underside of the ceiling

Note that the picture of the finishes provided is for illustrative purposes only. The finishes may vary in colour, texture and appearance. Contact Lucent lighting Ltd for more information.

It is the policy of Lucent Lighting to continually review and improve its products and therefore reserve the right to change any details of product or withdraw specifications without prior notice.

Luminaires designed to comply with EN60598 and all other standards.

This specification sheet supersededs all previous versions.

All intellectual property rights pertaining to the product described above and to this document are owned by or licensed to Lucent Lighting Ltd.

We reserve the right to take whatever action is necessary to protect those intellectual property rights.

Issued: 08/25