
## ProSpex Soft70 Colour Accent

TM65.2 9kgCO2e






90mm (3.54") overall trim diameter. 70mm (2.76") overall trimless diameter. 360° rotation. Up to 20° tilt. Available with standard trim kit or plaster-in kit for flush appearance. Family of matching products also available. Required depth height + 25mm^



073-C-LED-TR Cut-out 79mm Ø Trim kit



073-C-LED-TL Cut-out 79mm Ø Seamless flush appearance

LED Source	LED51TW	LED51TW
CCT range 5000K-2000K	@3000K	@3000K
Drive Current (max per channel)	700mA	700mA
Power inc Driver Max	15.1W	15.1W
Beam Angle	25°	35°
Delivered Lumens	644	679
Delivered Intensisty cd	2371	1389
Efficacy Im/w	43	45
Forward Volt (max per channel)	18.4V	18.4V
CRI	≥95 CRI	≥95 CRI

Apply these factors to 3000K for lumen output of other CCTs: 2000K x 0.67 / 2700K x 0.84 / 3500K x 1.085 / 4000K x 1.113 / 5000K x 1.087

## Soft Colour Inserts



Polished Copper



Piano Black



Polished Gold



Satin Gold



Polished Silver



Satin Silver

Issued: 04/25



Project Ref:		Location Ref:
Fixture Ord	er Code: 073-C-LED –	
Fixture – 073-C-LED	Soft70 Accent with LED51	
Installation – TR TL	Trim Trimless	
Colour Insert CP PB PG SG PS SS	Polished Copper Piano Black Polished Gold Satin Gold Polished Silver Satin Silver	
Trim Finish (Lo WH BK RAL	eave blank if trimless) ———————————————————————————————————	
LED Order	Code: LED51TW -	5020 -
LED – LED51TW	LED50 ONE Tuneable White	
CCT —	5000K - 2000K	
Beam — 25 35	25° 35°	
Driver Option  Protocol —  D6  D8  B	DALI Type 6** DALI Type 8** Bluetooth***	Emergency Options:  Emergency  Maintained 3hr Emergency ED  Maintained 3hr DALI Self Test ES  Maintained 3hr Self Test

Issued: 04/25

## **lucent**®







**Diffusing Lens** 



**Frosted Lens** 



**Heavy Spread Lens** 



**Linear Spread Lens** 

Accessories Order Code:

Louvre/Lens

LL45 Honeycomb Louvre LLDF Diffusing Lens LLFR Frosted Lens LLS Linear Spread Lens LLHS Heavy Spread Lens

**Technical Details** 

\*Custom RAL code must be specified. Custom RAL colours can increase prices and lead times

Dimming. Whilst Lucent can offer the majority of its luminaires with various dimming options, it remains the responsibility of the specifier/installer to check and ensure compatibility of any control equipment used. Additional cabling may be required depending on the dimming protocol specified.

- \*\*DALI Type 6 requires two DALI addresses, one for CCT control the other for Intesisty control. DALI Type 8 is a single DALI Type 8 address for CCT and Intesisty control. Please check which control system is being used before specifying.
- \*\*\*Bluetooth (wireless) is the communication method. The exact dimming protocol must be confirmed to allow the selection of suitable drivers or bluetooth devices.
- ^ Depth indicated is the minimum recess depth for the luminaire with a remote mounted LED driver. Installing a driver through either the luminaire cut-out or installation kit may require additional recess depth, please refer to the relevant luminaire installation instructions for further details. Data correct at time of publishing

First Fix Requirement. Luminaire comprised of fixture body with ceiling trim and installation kit, which is to be fitted into the ceiling once finished. Ensure correct alignment of the installation kit before final assembly (see luminaire instillation instructions for details)

IP Rating. Tested from underside of the ceiling

It is the policy of Lucent Lighting to continually review and improve its products and therefore reserve the right to change any details of product or withdraw specifications without prior notice.

Luminaires designed to comply with EN60598 and all other standards.

This specification sheet supersededs all previous versions.

All intellectual property rights pertaining to the product described above and to this document are owned by or licensed to Lucent Lighting Ltd.

We reserve the right to take whatever action is necessary to protect those intellectual property rights.

Please notify Lucent Lighting Ltd of any inaccuracies immediately. E&OE

Issued: 04/25